



Consumer and
Corporate Affairs Canada
Ottawa, Ontario
K1A 0C9

Consommation
et Corporations Canada

SPE-387

Year file: 1980

File no: 1689-1

File: G6589-H1

16 July 1980

SPECIAL APPROVAL

Granted To: Nova Scotia Power Corporation
Box 910, Halifax, N.S.
B3J 2W5

Attention: R.L. Mollon, P. Eng.
System EHV Design Engineer

Subject: Three only ASEA Type IMBA-145-A3
Current Transformers, 60 Hz,
600-5-5-5A, Ser. Nos. 6070753,
6070768 and 6070770.

Special Approval has been granted by the Legal Metrology Branch, for use of the "Z" coil of the subject transformers for billing purposes in Canada.

The accuracy rating of the approved coil is 0.6 B1.0 as marked on the nameplate.

These transformers will be used by Nova Scotia Power Corporation at their Onslow (1N) Substation.

J. Armstrong
Acting Chief
Electricity & Gas Division
Legal Metrology Branch

cc: Mr. A.K. Baldwin, Acting D.M., E&G Halifax