



Consumer and
Corporate Affairs Canada

Consommation
et Corporations Canada

Legal Metrology Branch
Ottawa, Ontario
K1A 0C9

SPE-388

Your file Votre référence

Our file Notre référence G6565-L1-3

21 July, 1980

SPECIAL APPROVAL

Granted to: Nova Scotia Power Corporation
 P. O. Box 910
 Halifax, Nova Scotia
 B3J 2W5

Attention: Mr. Norman Hutt,
Superintendent of Metering.

Subject: Landis & Gyr Type ZMRI.2 er 14 fl
 Solid State, Bi-directional, 3 element
 Transformer Rated Watt Hour Meter,
 Serial No. 45550516
 Stock No. 058925

Special Approval has been granted for use of the subject meter for revenue metering in Canada.

The Type ZMRI was approved in standard ratings under E-112, July 12, 1974; E-112-1, August 29, 1974, and E112-2, September 29, 1975.

The subject meter is transformer rated for a V.T. ratio of 79676: 66.4V and a C.T. ratio of 600-5A.

The two kWh registers have 7 digit dials and a multiplier of 1000. The right-hand (units) dial is marked in 100 divisions.

This meter is to be used by the Nova Scotia Power Corporation at their N.S.-N.B. Interconnection installation at Maccan, Nova Scotia.

D. L. Smith, Chief,
Electricity and Gas Division.

cc: Mr. A. K. Baldwin,
 C.C.A.C. Regional Office,
 Halifax, N. S.