



Your file Votre référence

Our file Notre référence G6565-F2-32

September 23, 1980

SPECIAL APPROVAL

Granted to: Ferranti-Packard Transformers Ltd,
P. O. Box 548,
St. Catharines, Ontario.
L2R 6W9

Attention: Mr. R. D. MacKimmie, P.Eng.,
Manager, Instrument Transformer
Design Engineering.

Subject: Eight only Ferranti-Packard Type RU-25
Current Transformers.
Four are 6000-5-5A, Serial Nos. 2-474588,
2-474589, 2-474590 and 2-474591,
and
Four are 1200-5-5A, Serial Nos. 2-474547,
2-474584, 2-474585 and 2-474586.

Special Approval has been granted by the Director,
Legal Metrology Branch, for use of the subject transformers
for revenue metering in Canada.

The accuracy rating is 0.3B2.0 .

Type RU-25 was approved under Notice of Approval No. T-19,
September 20, 1966, but the approval did not cover double
secondary coils and cores nor the 6000-5A rating.

These transformers will be used by Alcan at their
Beauharnois, Quebec, Substation.

D. L. Smith, Chief,
Electricity and Gas Division.

cc: Mr. P. Lebeau, District Manager,
Electricity and Gas,
Legal Metrology Branch - Montreal.
Aluminium du Canada Ltee, Montreal,
by way of Mr. P. Lebeau.