



Consumer and
Corporate Affairs Canada

Consommation et
Corporation Canada

Consumer Standards
Directorate

Direction générale
des normes

Legal Metrology Branch
Ottawa, Ontario
K1A 0C9

SPE-394

Your No. / Votre référence

Our No. / Notre référence G6565-C2-32

October 21, 1980

SPECIAL APPROVAL

Granted to: Canadian General Electric Co. Ltd
940 Lansdowne Avenue
Toronto, Ontario
M6B 3Z4

Attention: Mr. J. Gilliver, Specialist,
Marketing and Engineering Application,
Specialty Transformer Section.

Subject: Four only C.G.E. Type CTPL-15, 2400/1200-5A 60Hz
Current Transformers, Serial Numbers 1253914,
1253915, 1253916 and 1253917

Special Approval has been granted by the Director, Legal Metrology Branch, for use of the subject transformers for revenue metering in Canada. These transformers are electrically similar to Type CTPL-15 approved under Notice of Approval No. T-39 dated May 6, 1980, but that Notice of Approval does not cover the 2400/1200-5A current rating.

Secondary terminals X1 and X3 are used for the high ratio, while X1 and X2 are used for the low ratio. The name-plate accuracy rating is 0.3 B 0.9 for both ratios.

These transformers will be used by Ontario Hydro at General Abrasive Company, Niagara Falls.

D. L. Smith, Chief,
Electricity and Gas Division.

cc: Mr. W.J. Taggart,
District Manager,
Electricity and Gas - HAMILTON.

Ontario Hydro (via Mr. Taggart)