



Consumer and
Corporate Affairs Canada

Consommation et
Corporation Canada

Consumer Standards
Directorate

Direction générale
des normes

SPE- 395

Your file Votre référence

Our file Notre référence G6565-C377-32

October 27, 1980

SPECIAL APPROVAL

Granted to: Cegelec Alsthom Inc.
1400 Boulevard Industriel
Laprairie, Quebec
J5R 2E5

Attention: Mr. F. Lafrance

Subject: One only Alsthom-Savoisienne Type IH-765-13,
60 Hz, 765 kV, 1200/600-5-5A Current Trans-
former, Serial No. K 8393101A

Special Approval has been granted by the Director, Legal Metrology Branch, for the use of the subject transformer for revenue metering in Canada. This transformer is equipped with a single section primary and two separate secondary core and coil assemblies. Secondary terminals Y1 and Y2 are used for the 1200-5A rating, while Z1 and Z2 are used for the 600-5A rating.

The C.S.A. accuracy rating for both ratios is 0.3 B2.0.

This transformer will be used by Hydro-Québec at Chateauguay Substation, Quebec.

D. L. Smith, Chief,
Electricity and Gas Division.

cc: Mr. P. Lebeau,
District Manager,
Electricity and Gas - MONTREAL.

Hydro-Québec via Mr. P. Lebeau