



Consumer and
Corporate Affairs Canada

Consommation et
Corporation Canada

Consumer Standards
Directorate

Direction générale
des normes

SPE-396

Legal Metrology Branch
Ottawa, Ontario
K1A 0C9

Your file Votre référence

Our file Notre référence C6565-C3-32

October 28, 1980

SPECIAL APPROVAL

Granted to: Westinghouse Canada Ltd
 Box 5220
 London, Ontario
 N6A 4N6

Attention: Mr. T. W. Kolator, P.Eng.,
 Senior Engineer, Protective Products,
 Transformer and Distribution Apparatus
 Division, London, Ontario.

Subject: Three only Westinghouse Type RCT-15 Current
 Transformers, 3000/1500-5A, 60 Hz,
 Serial Numbers LE 70566, LE 70567 and LE 70568

Special Approval has been granted by the Director, Legal Metrology Branch, for use of the subject transformers for billing purposes in Canada. They are ring type transformers similar to the Type RCT approved under Notice of Approval No. T-15 dated October 4, 1966, which did not include the dual current rating covered by this notice.

The accuracy rating is 0.3B2.0 for the current ratios of 3000-5A and 1500-5A.

These transformers will be installed by Federal Pioneer Ltd of Regina, Saskatchewan, for Shell Canada, at Rosevear, Alberta.

D. L. Smith, Chief,
Electricity and Gas Division.

cc: Mr. L. Hewitt,
 District Manager,
 Electricity and Gas - CALGARY.

Federal Pioneer Ltd (via Mr. Hewitt)