



Consumer and  
Corporate Affairs Canada

Consommation et  
Corporation Canada

Consumer Standards  
Directorate

Direction générale  
des normes

SPE-397

Legal Metrology Branch  
Ottawa, Ontario  
K1A 0C9

File No. / Numéro de dossier

File No. / Numéro de dossier G6565-S1187

October 28, 1980

SPECIAL APPROVAL

Granted to: Markham Electric Ltd  
P. O, Box 276  
Agincourt, Ontario  
M1S 3B6

Attention: Darlene McIntyre

Subject: Two only Sadtem Type KT5-36 Current  
Transformers, 1600/800-5A,  
Serial Numbers 394777 and 394778

Special Approval has been granted by the Director,  
Legal Metrology Branch, for use of the subject transformers  
for revenue metering in Canada.

The accuracy rating is 0.3B0.9, 0.6B1.8 for both  
ratios and the rating factor (R.F.) is 1.33.

These transformers will be used by Ontario Hydro in  
the metering bay at Cyanamid Canada Ltd, Niagara Falls, Ont-  
ario.

D. L. Smith, Chief,  
Electricity and Gas Division.

cc: Mr. W. J. Taggart,  
District Manager,  
Electricity & Gas - HAMILTON

Ontario Hydro (Via Mr. Taggart)