



Consumer and
Corporate Affairs Canada
Legal Metrology Branch
Ottawa, Ontario
K1A 0C9

Consommation
et Corporations Canada

SPE-398

Your No. Votre référence

Our No. Notre référence G6565-7

December 15, 1980

SPECIAL APPROVAL

Granted to: B. C. Hydro & Power Authority,
325 Howe Street,
Vancouver, B. C.

Attention: Mr. Roy Hughes

Subject: Installation of U. S. Type Westinghouse
D4S Meters in Conjunction with Honeywell
Energy Cost Indicators (Trial)

Special approval is hereby granted to B. C. Hydro by the Director, Legal Metrology Branch, for the use of U. S. type domestic watt hour meters fitted with an approved pulse initiator and used in combination with the Honeywell Energy Cost Indicator.

The watt hour meters are Westinghouse D4S three wire domestic meters with only one test link and no test dial and are fitted with an approved pulse initiator, Type CDI-22. Two wire pulses are fed from the pulse initiator to a Honeywell Energy Cost Indicator which is programmed to display the energy consumed in terms of dollars.

The purpose of this trial, which involves up to one hundred meters, is to evaluate the influence of the Energy Cost Indicator on the average residential customer with respect to reduction of energy consumption.