



Legal Metrology Branch
Ottawa, Ontario
K1A 0C9

SPE -399

Your file / Votre référence

Our file / Notre référence G6565-1.1-5

December 10, 1980

SPECIAL APPROVAL

Granted to: Mississauga Hydro,
2325 Hurontario Street,
Mississauga, Ontario.
L5A 2G3

Attention: Mr. E. Finnegan,
Meter Shop Supervisor.

Subject: One only Landis & Gyr Reactive Energy Meter
Type FL34101hr3, Serial No. 45,533,258
120 Volts, 60 Hz, 0.12-10 amperes
Kh = 0.8 varh/revolution
Kp = 1 varh/impulse

Special Approval is hereby granted by the Director,
Legal Metrology Branch, for the use of the subject meter for
billing purposes in Canada.

This meter is similar to those previously approved
under Special Approval Notices SPE-363 and SPE-369 dated
April 24, 1979 and August 7, 1979 respectively except for
the Kp value. It will be installed by Mississauga Hydro at
Douglas Aircraft, Airport Road, Mississauga, Ontario.

D. L. Smith, P. Eng.,
Chief, Electricity and Gas Division.

cc: Mr. R.J. Leblanc,
National Sales Mgr.,
Landis & Gyr Products,
Landis & Gyr Division of Montel,
St. Laurent (Quebec).

Mr. M.D. Raaflaub,
District Mgr - Electricity and Gas,
Consumer and Corporate Affairs Canada,
Don Mills, Ontario.

The meters and indicators will be supplied by the United States Department of Energy, and the trial will last for a period of up to eighteen months. At the completion of the project, the meters and indicators are to be shipped to the Legal Metrology Branch for trans-shipment to the Department of Energy in Washington, D. C.

Approval for use of these meters is based on the assumption that regular manual meter readings will be used for billing purposes.

A handwritten signature in cursive script, appearing to read "D. L. Smith", with a horizontal line underneath the name.

D. L. Smith, P. Eng.,
Chief, Electricity and Gas
Division.

cc: Mr. W. Pura,
District Manager,
Electricity and Gas,
VANCOUVER.