



Legal Metrology Branch  
Standards Branch  
Holland Avenue  
Ottawa, Ontario  
K1A 0C9

SPE-402

Your file    Votre référence

Our file    Notre référence    G6565-U78-32

March 26, 1981

SPECIAL APPROVAL

Granted to:    Edmonton Power,  
600 Centennial Library,  
7 Sir Winston Churchill Square,  
Edmonton, Alberta.  
T5J 2V4

Attention:    Mr. Terry Hahn,  
System Communications Engineer.

Subject:        Six only, Balteau Type QDR 245, 60 Hz, 245 Kv  
Current Transformers, 1800/1200-5A,  
Serial Numbers 77/51.001/01 to 06

Special Approval is hereby granted by the Director,  
Legal Metrology Branch, for the use of the subject transformers  
for revenue metering in Canada.

The approved ratios are obtained from secondary terminals  
X<sub>1</sub> - X<sub>3</sub> and X<sub>2</sub> - X<sub>3</sub> and the accuracy rating is 0.3B2.0.

These transformers will be used by Edmonton Power at their  
Petrolia Substation, S.W. Corner of N.W. Quarter, Section  
1-52-25-W4th.

D. L. Smith, P. Eng.,  
Chief,  
Electricity and Gas Division.

cc:    Mr. F.W. Nash,  
District Manager,  
Electricity and Gas,  
EDMONTON, Alberta.

Edmonton Power (via Mr. Nash)