



Legal Metrology Branch
Standards Building
Holland Avenue
Ottawa, Ontario
K1A 0C9

SPE-403

File No. / Numéro

Order / Numéro G6565-B8-32

March 26, 1981

SPECIAL APPROVAL

Granted to: Edmonton Power,
600 Centennial Library,
7 Sir Winston Churchill Square,
Edmonton, Alberta.
T5J 2V4

Attention: Mr. Terry Hahn,
System Communications Engineer.

Subject: Three only, Brown Boveri, Type AOT 245 IA,
60 Hz, 245 Kv, Multicore and Multiratio
Current Transformers,
Serial Numbers 382919, 382924 and 382930

Special Approval has been granted by the Director,
Legal Metrology Branch, for use of the subject transformers
for revenue metering in Canada.

Only the 1600-5 and 1200-5 ratios, on Core 1,
Terminals X₁ - X₃ and X₂ - X₃, are approved under this notice
for revenue metering.

The accuracy rating is 0.3B2.0.

These transformers will be used by Edmonton Power at
their Jasper Terminal, 170 Street, 105 Avenue, Edmonton,
Alberta.

D. L. Smith, P. Eng.,
Chief,
Electricity and Gas Division.

cc: Mr. F.W. Nash,
District Manager,
Electricity and Gas,
EDMONTON, Alberta.

Edmonton Power (via Mr. Nash)