



Consumer and  
Corporate Affairs Canada

Consommation  
et Corporations Canada

Legal Metrology Branch  
Standards Building  
Holland Avenue  
Ottawa, Ontario  
K1A 0C9

SPE-404

Your file    Votre référence

Our file    Notre référence G6565-C377-32

SPECIAL APPROVAL

May 11, 1981

Granted to: Cegelec Alsthom Inc.  
1400 Boulevard Industriel  
Laprairie, Quebec  
J5R 2E5

Attention: Mr. F. Lafrance

Subject: One only Alsthom-Savoisienne,  
Type IH-765-13, 60 Hz, 765 KV,  
2000/1200/600-5-5-5A,  
Current Transformer, Serial No. 1

Special Approval has been granted by the Director, Legal Metrology Branch, for the use of the subject transformer for revenue metering in Canada. This transformer is equipped with a single section primary and two separate secondary core and coil assemblies. Secondary terminals X1 and X2 are used for the 2000-5A rating, and X2 and X3 on the same core are used for the 1200-5A rating. The 600-5A rating is obtained from a separate core and coil assembly, the terminals of which are designated Y1 and Y2.

The accuracy rating for all ratios is 0.3B2.0. This transformer will be used by Hydro Quebec at Chateauguay substation, Quebec.

D. L. Smith, P. Eng.,  
Chief,  
Electricity and Gas Division.

cc: Mr. P. Lebeau  
District Manager  
Electricity and Gas  
MONTREAL.

Hydro Québec  
(via Mr. P. Lebeau)