



Consumer and
Corporate Affairs
Canada

Consommation
et Corporations
Canada

Legal Metrology

Méetrologie Légale

SPE - 418

Approval No. d'approbation

Ottawa

1981-10-15

APPROBATION SPECIALE

SPECIAL APPROVAL

Accordée à:

Granted to:

ASEA Limited
C.P. 700
Succursale de Cartierville
Montréal (Québec)
H4K 2J8

ASEA Limited
Box 700
Postal Station Cartierville
Montreal, Quebec
H4K 2J8

A l'attention de
M. Pierre A. Tellier,
Service de l'électricité

Attention: Mr. Pierre A. Tellier,
Power Department.

L. K. Waclawik, P. Eng.

Chef intérimaire
Division de l'électricité et du gaz
Direction de la Métrologie légale
Edifice des normes
Avenue Holland
Ottawa (Ontario)
K1A 0C9

Acting Chief
Electricity and Gas Division
Legal Metrology Branch
Standards Building
Holland Avenue
Ottawa, Ontario
K1A 0C9

APPROBATION SPECIALE 418

Objet: Quatre modèles seulement de transformateurs
d'intensité ASEA du type IMBD 170 A1, 200-400/5A
60 Hz, numéros de série 7236 133 à 136

Une approbation spéciale a été accordée par le
Directeur de la Métrologie légale concernant l'utilisation
au Canada des transformateurs précités à des fins de
facturation.

Le taux d'exactitude est de 0.3B2.0 pour l'évaluation
400-5 et de 0.3B1.0 pour le 200-5A, à un facteur RF1.2.

Ces transformateurs seront installés par l'Alcan pour
Domtar à Dolbeau (Québec).

Réf.: G6565-C4-32

c.c.: P. Lebeau
Gérant de district
Electricité et gaz (Montréal)

Alcan (par l'entremise de M. Lebeau)

SPECIAL APPROVAL 418

Subject: Four only ASEA Type IMBD 170 A1
Current Transformers, 200-400/5A, 60 Hz
Serial Numbers 7236 133 to 136

Special approval has been granted by the Director,
Legal Metrology Branch, for use of the subject transformers
for revenue metering in Canada.

The accuracy rating is 0.3B2.0 for the 400-5A rating
and 0.3B1.0 for the 200-5A. The rating factor is RF1.2.

These transformers will be installed by Alcan for
Domtar, at Dolbeau, Quebec.

Ref: G6565-C4-32

cc: P. Lebeau
District Manager
Electricity and Gas (Montreal)

Alcan (via Mr. Lebeau)