



Consumer and  
Corporate Affairs  
Canada

Consommation  
et Corporations  
Canada

Legal Metrology

Métrieologie Légale

SPE-427

Approval No. d'approbation

Ottawa

NOV 9 1982

NOTICE OF APPROVAL – AVIS D'APPROBATION

WESTINGHOUSE TYPE RTCT CURRENT  
TRANSFORMER

Manufacturer: Westinghouse Canada Inc.,  
Box 5220  
London, Ontario  
N6A 4N6

Description: Six only Westinghouse type  
RTCT current transformers, 4000/3000/  
2000/1000-5A, 60Hz, serial no. LJ79990 to  
LJ79995 inclusive.

These transformers are of a toroidal  
design and will be installed on the  
bushings of power transformers.

Accuracy Rating: Approved for metering  
on the 4000-5A ratio (taps X1, X4) only,  
at 0.3B2.0

Installation Address: These transformers  
are to be used by Campbell Red Lake Mines  
Limited and will be located at their  
Detour Lake Project in Northern Ontario.

TRANSFORMATEUR D'INTENSITE WESTINGHOUSE  
TYPE RTCT

Fabricant: Westinghouse Canada Inc.  
Box 5220  
London, Ontario  
N6A 4N6

Description: Six transformateurs  
d'intensité Westinghouse, type RTCT, de  
4000/3000/2000/1000-5A, 60 Hz, portant  
les numéros de série allant de LJ79990 à  
LJ799995 inclusivement.

Ces transformateurs sont de forme  
toroïdale et seront fixés aux  
transversées des transformateurs de  
puissance.

Précision nominale: Ils sont approuvés  
pour un rapport de mesure de 4000-5A  
(prises X1, X4) uniquement, à une  
précision nominale de 0.3B2.0.

Emplacement: Ces transformateurs seront  
utilisés par la Campbell Red Lake Mines  
Limited au Detour Lake Project dans le  
nord de l'Ontario.