



Ottawa JAN 11 1983

NOTICE OF APPROVAL – AVIS D'APPROBATION

Type CV-1 Capacitor Voltage Transformer

Company: Manitoba Hydro
Box 815
Winnipeg, Manitoba
R3C 2P4

Manufacturer: Canadian General Electric
Company Limited
201 Woodlawn Road West
Guelph, Ontario
N1H 1B8

Description: Four only type CV-1
Capacitor Voltage Transformers, 230,000
and Y/138,000 - 115/69 - 115/69 volts,
60Hz, serial numbers 788422, 423, 424 and
430.

The above units are the same as those
described in SPE-212, 213, 234, 246 and
257.

This approval is valid only for the
following connections:

Serial 788422

L4 - H3 to 1A; 2 to 7; 3 to H
T1 - Line to H; D to E; G to ground
Intermediate Transformer T1, serial
768713

Serial 788423

L4 - H3 to 1A; 2 to 7; 4 to H
T1 - Line to H1; G to C; D to ground
Intermediate Transformer T1, Serial
770419

Serial 788424

L4 - H3 to 1A; 2 to 4; 3 to E
T1 - Line to H1; E to D; F to ground
Intermediate Transformer T1, Serial
770412

Transformateur condensateur de tension
CV-1

Société: Manitoba Hydro
Box 815
Winnipeg, Manitoba
R3C 2P4

Fabricant: Canadian General Electric
Company Limited
201 Woodlawn Road West
Guelph, Ontario
N1H 1B8

Description: Seulement quatre transfor-
mateurs condensateurs de tension CV-1,
étoile à la terre 230 000/138 000 -
115/69 - 115/69 volts, 60Hz portant les
numéros de série 788422, 423, 424 et 430.

Les appareils susmentionnés sont
identiques à ceux décrits dans les avis
SPR-212, 213, 234, 246 et 257.

La présente approbation ne vise que les
connexions suivantes:

Série 788422

L4 - H3 à 1A; 2 à 7; 3 à H
T1 - Ligne à H; D à E; G à la terre
Transformateur intermédiaire T1, série
768713

Série 788423

L4 - H3 à 1A; 2 à 7; 3 à H
T1 - Ligne à H1; G à C; D à la terre
Transformateur intermédiaire T1, série
770419

Série 788424

L4 - H3 à 1A; 2 à 4; 3 à E
T1 - Ligne à H1; E à D; F à la terre
Transformateur intermédiaire T1, série
770412