



Consumer and
Corporate Affairs Canada

Legal Metrology

Consommation
et Corporations Canada

Métrieologie léale

APPROVAL No. - N° D'APPROBATION

SPE-437

NOV 14 1983

NOTICE OF APPROVAL

AVIS D'APPROBATION

Westinghouse Type PTD-15, Voltage
Transformers

Transformateurs de tension PTD-15, de
Westinghouse

Company: Federal Pioneer Limited
101 Rockman Street
Winnipeg, Manitoba
R3T 0L7

Société: Federal Pioneer Limited
101 Rockman Street
Winnipeg, Manitoba
R3T 0L7

Manufacturer: Westinghouse Canada Inc.
London, Ontario

Fabricant: Westinghouse Canada Inc.
London, Ontario

Description: Seven only, Westinghouse
voltage transformers, Type PTD-15, ratio
8400-120-70V, Serial Numbers LK65351,
LK65363 to LK65368.

Description: Sept transformateurs de
tension Westinghouse PTD-15 à rapports
de 8400-120-70 V, portant les numéros de
série LK65351 et LK65363 à LK65368.

The accuracy rating at 60 Hz is 0.6z -
0.6z for both ratios.

La classe de précision à 60 Hz est de
0.6z-0.6z pour les deux rapports.

Frequency: 60 Hz

Fréquence: 60 Hz

Insulation Class: 15kV

Classe d'isolation: 15 kV

BIL (Basic Impulse Level): 110 kV

Tension de tenue au choc (BIL): 110 kV

Installation Address: The transformers
will be used by Ontario Hydro at their
Toronto - Dufferin Substation.

Emplacement d'installation: Les trans-
formateurs seront utilisés par l'Ontario
Hydro à leur sous-station de Dufferin, à
Toronto.

.../2