



TRADE AND COMMERCE
CANADA

SD-GA.115

STANDARDS DIVISION

OTTAWA,..... February 4, 1957.

TYPE APPROVAL

ROCKWELL #2½ CAST IRON CASE
POSITIVE DISPLACEMENT GAS METER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Gas Inspection Act, Chapter 129, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Rockwell #2½ Cast Iron Case Positive Displacement Gas Meter, manufactured by the Rockwell Manufacturing Company, Pittsburgh, Pa., and distributed in Canada by its subsidiary, the Rockwell Manufacturing Co. of Canada Ltd., Guelph, Ontario.

Rating of Apparatus:

Badged Capacity	720 cu.ft./hr.(air)
Differential Pressure at badged capacity	0.5" water gauge
Capacity per revolution	0.77 cu.ft.
Connections	2" female.

Application: Measurement in distribution service of manufactured, natural, and petroleum gases, or mixtures thereof.

Description: The instrument approved herewith is essentially the same in design and appearance as the #4 previously approved, January 17, 1957, in Circular SD-GA.112.

E. F. Power

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean
R. W. MacLean,
Director,
Standards Division.

Ref: A-622