



TRADE AND COMMERCE
CANADA

SD-GA.121

STANDARDS DIVISION

OTTAWA, June 12, 1957.

TYPE APPROVAL

BEGWACO BANTAM "2000" STEELCASE
POSITIVE DISPLACEMENT GAS METER

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Gas Inspection Act, Chapter 129, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Begwaco Bantam "2000" Steelcase Positive Displacement Gas Meter, manufactured and distributed in Canada by Begwaco Meters (Canada) Limited, No. 40 Highway, Chatham, Ontario.

Rating of Apparatus:

Badged Capacity 1500 cu.ft./hr.(air)
Differential Pressure at badged capacity 0.5" water gauge
Capacity per revolution 1.25 cu.ft.
Connections 2" female.

Application: Measurement in distribution service of manufactured, natural, and petroleum gases, or mixtures thereof.

Description: Welded steel case, with die cast diaphragm chambers and gas way. Bakelite valves and seats. Leather or synthetic diaphragms.

E. F. Power

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean
R. W. MacLean,
Director,
Standards Division.

Ref: A-643