

DEPARTMENT OF TRADE AND COMMERCE

STANDARDS BRANCH

SPG - 3

File: SL-100-SPG.3
6E-85-40

OTTAWA, April 29, 1965.

TO: Canadian Meter Company Limited,
Milton, Ontario.

RECORDS

MAY 4 1965

Re: American Type B.t.u. Meter, Series 210

I & C PA 16

Special Approval has been granted by the Standards Branch on the American Type B.t.u. meter for use in Canada. This instrument is basically a device which determines the heat loss (or gain) in a measured stream of flowing water and its function is comparable to other types of energy meters.

It is the responsibility of the distributor of this instrument to advise the District Inspector of Electricity and Gas the location of these meters when sold.

No inspection of these meters will be required except in the case of dispute. The inspection fee is \$5.00.

Approval granted to: Canadian Meter Company Limited, Milton, Ontario.

K. Cryer

(K. Cryer)
Chief, Electricity and Gas Division.

KO/mee

c.c. to: All District Inspectors of Electricity and Gas

