

810-42

SE-85-41  
SL-100-478  
SL-100-816

OTTAWA, January 28, 1970.

Special Approval

Granted to: Consumers' Gas Company,  
19 Toronto Street,  
Toronto 1, Ontario.

Subject: Rockwell Model T-140-10" Turbo Meter with attached  
Mercury Model 832-1 VFT Gauge.

Attention: Mr. F. Davis,  
Superintendent of Measurement.

Special approval is hereby granted by the Standards Branch of the Department of Consumer and Corporate Affairs to Consumers' Gas Company to use the following gas metering equipment to be installed at Canadian General Electric Company, Lansdowne Ave., Peterborough, Ontario:

1. Rockwell Model T-140-10" Turbo Meter 125 psig
  - Serial No. 1000046
  - Inspection No. 400942
2. Mercury Model 832-1, Volume-Pressure-Temperature Gauge
  - Serial No. CP 092334
  - Inspection No. VFT 345
  - Range: 0-90 psi; -30° to 140°F

The average load estimate for this installation 70,000 cfh.  
The maximum load estimate for this installation 210,000 cfh.

Inlet pressure range 11 to 35 psig.

*W. J. S. Fraser*  
W. J. S. Fraser,  
Chief, Electricity and Gas Division.

c.c. Mr. J. H. McEown, S.I. of I&S, Toronto  
Mr. J. H. Kokesh, Regional Manager, Toronto.  
Rockwell Manufacturing Company of Canada Ltd. (through Mr. McEown)

