

SP 6-49

OTTAWA, April 24, 1970.

SPR-19
SE-85-56
SL-100-85
SL-100-85G

SPECIAL APPROVAL

Granted to: Consumers Gas Company,
19 Toronto Street,
Toronto 1, Ontario.

Subject: Parkinson & Cowan Fluxi Turbine Gas Meter
Model 113 (rated 113,000 cfh) maximum rated
working pressure 275 psig. Serial #015119

Attention: Mr. D. M. Davis,
Superintendent of Measurement
Consumers Gas Company.

Special Approval has been granted by the Standards Branch to Consumers Gas Company for the use of a Model 113 "Fluxi" meter at a working pressure of 3 psig.

This 1 1/2" meter is to be installed at Colgate-Palmolive Ltd., Carlaw/Colgate Ave., Toronto, Ontario. It will be fitted with a Mercury P.V.T. instrument having a range of -30° to 120°F on temperature and 0-15 psi on pressure. The flexible drive connection - 1000 cu. ft./rev. Index Test Dial - 1000 cu. ft. Scallop - 100,000 or 1,000,000 cu. ft.

The utility shall provide the necessary facilities so that an inspector of the Department can inspect and test the meter either "in site" or in the meter shop.

A.J.D. Fraser,
Chief, Electricity and Gas Division.

c.c. Parkinson & Cowan (Canada) Ltd., Chatham, Ont.
Mr. J. Fleming, D.I. of E&G, London
Mr. W. K. McEown, D.I. of E&G, Toronto.

