

SIQ-53

SI-100-SIQ
SI-85-G

OTTAWA, June 5, 1970.

TEMPORARY SPECIAL APPROVAL

Granted to: S.R. & B. Rural Gas Co-op Limited,
Scandia, Alberta.

Subject: Metering of Farm Distribution Services at
Distribution Pressure of 5 psig.

Attention: Mr. E. Anderson,
Manager,
S.R. & B. Rural Gas Co-op Limited.

Temporary special approval is hereby granted by the Standards Branch, to S.R. & B. Rural Gas Co-op Limited, to meter thirty-one farm services at the distribution pressure of 5 psig.

The gas shall be metered by diaphragm type gas meters with ordinary registers and a multiplier of 1.33 applied to the registration of the meter to give the number of cubic feet consumed at base pressure.

The regulators on these systems shall be so adjusted and set as to give a static pressure at the inlet of the meters of 5 psig or higher, over the normal range of inlet pressure to the regulators. The contract with each consumer shall show the pressure at which the gas is metered, the base pressure and the multiplying factor to be applied to the reading of the meter.

These services may be subject to "spot checks" by the Electricity and Gas Inspection Services at any time with reasonable notice to the utility. The utility shall furnish the District Office with the names and addresses of the thirty-one farms covered by this approval and identify the type of regulator used in each case.

Reliance No. 268 Regulators (per Can. Meter Co. Ltd.)

(for) W.J.S. Fraser,
Chief,
Electricity and Gas Div.,
Standards Branch.

cc: Mr. C.G. Mathieu
Mr. A.S. Park
Mr. L.K. MacLewick

