

SPG-56

SE-85-41

SL-100-978

SL-100-8FD

OTTAWA, June 18, 1970.

SPECIAL APPROVAL

Granted to: Union Gas Company (Canada) Ltd.,  
Chatham, Ontario.

Subject: Rockwell Type T-140-10", 125 psi,  
Gas Turbo Meter

Attention: Mr. J. A. Reid,  
Union Gas Company (Canada) Ltd.

Special Approval has been granted by the Standards Branch to Union Gas Company for an installation of one T-140, 10 inch size Turbo meter, Serial No. 1000137, at Dominion Tar and Chemical Co. Ltd., Lot No. 11 Broken Front Concession Oxford west, No. 2 Highway, Beechville.

This meter is equipped with an American Volume Pressure and Temperature Gauge which has the following basic data:

Pressure range	0 - 100 psi
Temperature range	-30°F to +120°F
Base pressure	14.65 psia
Base temperature	60°F
Instrument drive capacity	1,000 cu. ft. per rev.

Other, estimated, operating conditions for this installation are as follows:

Average load	100,000 cu. ft. per hour
Minimum load	7,000 cu. ft. per hour
Pressure range	30 to 60 psig
Average pressure	35 psig
Temperature range	+30°F to +70°F





