

SPG-63

SL-100-G

SE-85-G

OTTAWA, July 22, 1970.

SPECIAL APPROVAL

Granted to: Canadian Western Natural Gas Co. Ltd.,  
140 - Sixth Avenue Southwest,  
Calgary 1, Alberta.

Subject: Use of Pressure Factor in Gas  
Metering Installation.

Attention: Mr. A. A. Stodalka, P. Eng.,  
Superintendent of Measurement,  
Canadian Western Natural Gas Co.

Special Approval has been granted by the Standards Branch to Canadian Western Natural Gas Company Limited to apply a pressure factor in the measurement of gas at the following installation under the stated conditions:

Customer - W. Holtman (Shipwheel Ranching)  
Address - Box 501, Barnwell, Alberta  
Nature of Load - Residence and three Hog Barns

Load - 1,000 c.f.h.

Service line pressure - 40 to 50 pounds

Metering pressure - 10 p.s.i.

Upstream Regulator - 1" Fisher 631

Meter - AL 800 T.C.

Pressure correction factor -  $\frac{10 + 13.0}{13.25} = 1.736$

W.J.S. Fraser,  
Chief, Electricity and Gas Division.

c.c. Mr. A. S. Park

