



SFG-78

SE-85-10
SL-100-91
SL-100-Spg

OTTAWA, October 7, 1970.

SPECIAL APPROVAL

Granted to: Consumers Gas Company,
19 Toronto Street,
Toronto 1, Ontario.

Attention: Mr. Don Davis,
Superintendent of Measurement.

Subject: Canadian Meter Base Volume Index Continuous
Integrator-Model 200 With Printout

Special Approval is hereby granted by the Standards Branch to Consumers Gas Company to use the following instrument in the measurement of gas:

Canadian Meter Base Volume Index, Continuous Integrator
Model 200 with printout
Instrument Location - Canada Wallpaper - 222 - 7th Street,
New Toronto
Serial # PP-2-139
Company No. C.I. #1
Temperature Range -20°F to +140°F
Pressure Range 0 to 100 PSIG
Base Temperature 60°F
Atmospheric Pressure 14.65 PSIA
Base Pressure 14.73 PSIA
Corrected counter reads 1000 cu. ft.
Uncorrected counter reads 100 cu. ft.
No supercompressibility factor
To be used on American 500 BIC - #190428
To be installed outside
To be sealed in Milton.

W.J.S. Fraser,
Chief, Electricity & Gas Division.

c.c. Mr. J.A. Orwin - Milton
Mr. J. W. Ostler - Milton
Mr. R. N. Beattie - Hamilton
Mr. W. R. McEown - Toronto

Standards Branch
Direction des normes

