



SPG-79

SL-100-5
SL-85-G

OTTAWA, October 30, 1970.

SPECIAL APPROVAL

Granted to: Canadian Western Natural Gas Co. Ltd.,
140-Sixth Avenue Southwest,
Calgary 1, Alberta.

Attention: Mr. A. A. Stodalka, P. Eng.,
Superintendent of Measurement,
Customer Service & Utilization.

Subject: Use of Pressure Factor in Gas
Metering Installation.

Special Approval has been granted by the Standards Branch to Canadian Western Natural Gas Company Limited to apply a pressure factor in the measurement of gas at the following installation under the stated conditions:

Customer - Mr. K. Reimer
Address - Box 116, Linden, Alberta
Nature of Load - Residence and Broiler Barn

Load - 540 c.f.h.
Service line pressure - 30 p.s.i.
Metering pressure - 10 p.s.i.
Upstream Regulator - Reliance 268 5/16" ϕ
Meter - AL425 25# W.P.
Pressure correction factor - $\frac{10 + 13.0}{13.25} = 1.736$

Relief Valve - 1" Fisher 289H.

W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. A. S. Park

Standards Branch
Direction des normes

