

SPC-96  
REV-96

0-1000-1  
1-1000-1  
1-1000-1

OTTAWA, January 12, 1971.

MEMORANDUM TO THE HONOURABLE

Directed to: Canadian Meter & Instrument Co. Company Limited,  
140-Clack Avenue, Downsview,  
Ontario, Canada.

Attention: Mr. A. A. Seccombe, P. Eng.,  
Superintendent of Accounting,  
Customer Service & Installation

Subject: Use of Pressure Meter in Gas  
Metering Installation

Temporary Special Approval has been granted by the Commission  
Branch of Canadian Meter & Instrument Co. Company Limited, to apply a  
pressure factor in the measurement of gas at the following meter location  
under the stated conditions:


Customer - Mr. P. G. Lobo  
Address - Box 21, Crossfield, Alberta  
Nature of Load - Residence furnace and water heater,  
2 chicken barns heating and water  
heating, Garage.

Load - 960 c.f.h.  
Service line pressure - 40 to 50 p.s.i.  
Metering pressure - 10 p.s.i.  
Upstream regulator - 1" Fisher 431-5 - 3/16" orifice  
Meter - Canadian Meter Model 4400 - 207mm.P.  
Pressure correction factor -  $10 + \frac{13.0}{13.25} = 1.796$   
Relief Valve - 1" Fisher 207H

This service may be subject to "spot checks" by Electricity and  
Gas Inspection Service at any time with reasonable notice.



This approval is temporary and will expire when permanent regulations pertaining to pressure factor measurement are put into effect.



W. J. B. Fraser,  
Chief,  
Electricity and Gas Division.

c.c. Mr. A. S. Park, D.I. of E&G, Calgary.  
Mr. N. H. Young, Regional Supervisor, E&G, Winnipeg.

