




Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPG-112

SE-85-56

SL-100-85

SL-100-SPG

OTTAWA, May 12, 1971.

SPECIAL APPROVAL

Granted to: United Gas Limited,
360 Strathearne Ave. N.,
Hamilton, Ontario.

Attention: Mr. Jerry Peters

Subject: Parkinson & Cowan - 8" Model, 600 ASA "Fluxi"
Axial Flow Turbine Meter

Special Approval has been granted by the Standards Branch to United Gas Limited for the installation of one 8" - 600 ASA Flanged Compagnie Des Compteurs "Fluxi" Turbine Gas Meter at Dominion Foundry and Steel, Burlington, Ontario. This meter will be fitted with a Canadian Meter Base Volume Index Continuous Integrator to correct for variations in line pressure and temperature.

Details of the meter are:

Model #	56
Company No.	21835
Serial No.	518109
Rated Capacity	56000 cfh
Meter Pressure - Max.	300 psig
- Normal	180 psig
Meter equipped with Canadian Meter Continuous Integrator	
Model	200
Pressure Range	0-300 psig
Temperature Range	-30° F to +120° F

W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Parkinson-Cowan (Canada) Ltd.
Mr. W. R. McEown, D.I. of E&G, Toronto
Mr. R.N. Beattie, D.I. of E&G, Hamilton

