



Department of consumer and corporate affairs / Ministère de la consommation et des corporations

SPG-101

SE-27  
SL-100-SPG

OTTAWA, October 8, 1971.

TEMPORARY SPECIAL APPROVAL

Granted to: Alder Flats Gas Co-op. Ltd.,  
Alder Flats, Alberta.

Attention: Mr. G. Foss, Secretary,  
Alder Flats Gas Co-op.

Subject: Use of Pressure Factor in Gas  
Metering Installation.

Temporary Special Approval has been granted by the Standards Branch to Alder Flats Gas Co-op., to apply a pressure factor in the measurement of gas at the following installations. The following information applies to all services.

Estimated load range - 0-250 CFHR  
Nature of load - Farm service  
Inlet pressure range of regulator - 45-50 psi  
Metering pressure - 5 psi  
Make of regulator - Reliance  
Type of regulator - 268  
Regulator orifice size - 5/16 inch  
Meter type - Parkinson Cowan B250 Positive Displacement  
Base Pressure - 14.65  
Atmospheric pressure - 13.50  
Pressure Factor - 1.261

<u>Name of Customer</u>	<u>Address</u>
E. Miller	Alder Flats
G. Shanks	Alder Flats
N. Moore	Alder Flats
V. Forchuk - two locations	Alder Flats
D. Sargent	Alder Flats
T. Maciborski	Alder Flats
F. Foster	Alder Flats
L. Poudrier	Alder Flats
M. Poudrier	Alder Flats



R. Tomkin	Buck Lake
R. Wennerstrom	Alder Flats
D. Parker	Buck Lake
R. Parker	Buck Lake
C. Parker	Buck Lake
O. Knight	Alder Flats
C. Hammond	Alder Flats
M. Trussett	Buck Lake
G. Poszgai	Buck Lake
Mrs. L. Fricke	Buck Lake
M. Dawson	Buck Lake
A. Kellgren	Alder Flats

This service may be subject to "spot checks" by the Electricity and Gas Inspection Service at any time with reasonable notice.

This approval is temporary and will expire when permanent regulations pertaining to pressure factor measurement are put into effect.

*W. J. S. Fraser*

W.J.S. Fraser,  
Chief,  
Electricity and Gas Division,  
Standards Branch.

c.c. Mr. J. Taylor, D.I. of E&G, Edmonton

*Mr. J. Taylor, D.I. of E&G, Edmonton*

