



SPG-144

1147-57/C6-M28  
SL-100-123  
SL-100-SPG

OTTAWA, December 30, 1971.

SPECIAL APPROVAL

Granted to: Kneehill Gas Co-op.,  
Kneehill, Alberta.  
Attention: Mr. E. L. Britton,  
Agent.  
Subject: Canadian Type 3.5CVM 300 High  
Pressure Rotary Meter.

Special Approval has been granted by the Standards Branch to Kneehill Gas Co-operative for the installation of one Canadian Type 3.5 CVM 300 high pressure rotary meter. Other details of the meter and auxiliary attachments are:

Rotary Meter

Company Number 108  
Serial Number 52547  
Rated Working Pressure 300 psig  
Load - Maximum 400 MCF/day  
Load - Minimum 100 MCF/day  
Drive 10 c.f. per rev.

Base Pressure Index (cam type) and Volume, Pressure, Temperature Gauge

Base pressure 14.4 psia  
Atmospheric Pressure 13.25 psia  
Temperature Range 0-150°F  
Base Temperature 60°F

W.J.S. Fraser,  
Chief, Electricity & Gas Division.

c.c. Canadian Meter Company  
Mr. N. Beattie, Hamilton  
Mr. A. S. Park, Calgary  
Mr. W. A. Sayers, Winnipeg.

