



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPG-145

1147-57/C6-M28

SL-100-123

SL-100-Spg

OTTAWA, December 30, 1971.

SPECIAL APPROVAL

Granted to: The Alberta Gas Trunk Line Company,
505 Second Street S.W.,
P.O. Box 2535. *Calgary Alta.*

Attention: Mr. T. N. Belus, P. Eng.,
Measurement Superintendent.

Subject: Canadian Type 3.5 CVM 1440 High
Pressure Rotary Meter.

Special Approval has been granted by the Standards Branch to The Alberta Gas Trunk Line Company for the installation of one Canadian Type 3.5 CVM 1440 high pressure rotary meter. The meter is to be located at a sales point on the company system designated as the NW $\frac{1}{4}$ of Section 9, Township 63 and Range 11, West of the Fifth Meridian. Other details of the meter and auxiliary attachments are:

Rotary Meter

Company Number	20-122
Serial Number	C-5659
Maximum rated pressure	1440 psig
Normal line pressure	800-900 psig
Normal line temperature	50° - 60°F
Estimated load	3,000,000 c.f./day

Base Pressure Index

Manufacturer - Canadian	<i>20-122</i>
Maximum Working Pressure	- 1000 psig
Base Pressure	- 14.4 psia
Average Atmos. Pressure	- 13.5 psia

Volume, Pressure, Temperature Recorder

VPT-1 0-12-1944

Manufacturer - Canadian
Maximum Working Pressure - 1500 psig
Temperature Range - 0°F to 150°F
Marker Arm Setting - 10,000 cu. ft.

W. J. S. Fraser

W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Canadian Meter Company
Mr. N. Beattie, Hamilton
Mr. A. S. Park, Calgary
Mr. W. A. Sayers, Winnipeg

