



SPC-177
1147-4
SL-100-112

OTTAWA, July 28, 1972.

SPECIAL APPROVAL

Granted to: Greater Winnipeg Gas Company,
265 Notre Dame Avenue,
Winnipeg 2, Manitoba.

Attention: Mr. W. Ferguson,
Superintendent of Operations.

Subject: Canadian Meter Type 12GT-150M
Turbine Meter rated 125 psig.

Special Approval has been granted by the Standards Branch to Greater Winnipeg Gas for the installation of a Canadian Type 12GT-150M High Pressure Turbine Meter rated at 125 psig. Details of the meter and auxiliary attachments are as follows:

Company Number	134501
Meter Body Number	PP-8037
Serial Number (Cartridge)	PP-C-112
Maximum rated pressure	125 psig
Normal line pressure	30 psig
Normal line temperature	50°F
Estimated load	220,000 scfh

The meter is fitted with a Canadian Model 100 BVI-CI.

Maximum working pressure	100 psig
Base pressure	14.55 psia
Atmospheric pressure	14.30 psia

The above complete with pulse flow rate equipment.

The installation is to be located at Dominion Malting Company, Transcona, Manitoba.

W. J. S. Fraser
W.J.S. Fraser,
Chief, Electricity & Gas Division.

c.c. Mr. W. A. Sayers
Mr. R. N. Beattie
Canadian Meter Company

