

Department of consumer and corporate affairs/Ministère de la consommation et des corporations



SPG-202

1147-4

3585-3

OTTAWA, November 22, 1972

## TEMPORARY SPECIAL APPROVAL

Granted to: Canadian Western Natural Gas Company Limited,

140-Sixth Avenue Southwest,

Calgary, Alberta.

Attention: Mr. A. A. Stodalka, P. Eng.,

Superintendent, of Measurement.

Subject: Use of Pressure Factor in Gas

Metering Installation

Temporary Special Approval has been granted by the Standards Branch to Canadian Western Natural Gas Company Limited, to apply a pressure factor in the measurement of gas at the following installation under the stated conditions:

Name Broxburn Feeders Ltd.

Address Box 1078, Coaldale, Alberta

Nature of Load Agricultural Location SE 1/4 1-9-21-4

Load 1,255 scfh
Service Line Pressure50 psig maximum

Metering Pressure 10 psig set at 1,000 scfh with

40 psig inlet

Upstream Regulator Sprague CL-31, d/16" Ø Black Spring

Relief Valve 1" Fisher 289H set at 15 psig Meter Parkinson Cowan B900 35# W.P.

Base Pressure 13.25 psia

Average atmospheric

Pressure 13.00 psia Pressure Correction

Factor  $\frac{13.00 + 10.00}{13.25} = 1.736$ 

This service may be subject to "spot checks" by the Electricity and Gas Inspection Service at any time with reasonable notice.

Standards Branch

Direction des normes

This approval is temporary and will expire when permanent regulations pertaining to pressure factor measurement are put into effect.

The Alexander

W.J.S. Fraser, Chief, Electricity and Gas Division.

c.c. Mr. A. S. Park Mr. J. Bileski