



Department of consumer and corporate affairs / Ministère de la consommation et des corporations

SPG-218

GL 1147-57/C6-112

G 1147-57/C6-112

OTTAWA, November 29, 1973.

SPECIAL APPROVAL

Granted to: Saskatchewan Power Corporation,  
Scarth Street & Victoria Ave.,  
Regina, Sask.

Attention: Mr. D. F. Campbell,  
Technical Services.

Subject: Canadian Meter Type GT-4 rated 1440 psig

Special Approval has been granted by the Standards Branch to Saskatchewan Power Corporation to install a Canadian Type GT-4 High Pressure Gas Turbine meter rated at 1440 psig. Details of the meter and attachment are as follows:

SPC Company Number	29698
Meter body number	73-F11817
Cartridge number	M-7976
Normal Operating Line Pressure	800-900 psig
Normal Operating Line Temperature	28°F - 52°F (ambient)
Estimated Load	6-10 million scf/day

The meter is fitted with a Canadian BVI-CI the details for which are as follows:

SPC Company Number	240
Maximum Working Pressure	900 psig
Atmospheric Pressure	13.65 psia
Base Pressure	13.9 psia
Base Temperature	60°F

The installation is located at Wymark, Saskatchewan.

W.J.S. Fraser,  
Chief,  
Electricity and Gas Division.

c.c Canadian Meter Company  
Mr. R. N. Scattie, Hamilton  
Mr. J. M. Taylor, Winnipeg  
Mr. J. Duff, Regina

Standards Branch  
Direction des normes