



STANDARDS DIVISION

OTTAWA, September 21, 1955.

APPROVAL LISTING

Gasoline dispenser - Manufactured by Bowser Inc., Ft. Wayne, Indiana, U.S.A., and S.F. Bowser Co. Limited, Hamilton, Ontario.

Under the provisions of the Weights and Measures Act, Chapter 292, R.S.C. 1952, and Regulations thereunder (P.C. 6894), the apparatus specified and illustrated herein have been listed as approved devices and may be used in Canada in accordance with the conditions applicable.

Apparatus Listed: Computing gasoline dispenser, Models 585-C and 595-C.


Rating of Apparatus: 15 G.P.M.


Application: Retail gasoline trade.

Conditions: As prescribed in P.C. 6894.


Description: These devices are similar in general design to models 577TV and 577TVC listed on SD-WA.219 except that:
(i) The air separator is located on the top of the meter
(ii) The float chamber is a separate unit
(iii) The pump manifold has been changed.
Model 585-C differs from Model 595-C in the method of hose retraction only.

Testing: The standard tests for a retail gasoline dispenser shall apply.



C.S. Phillips,
Assistant Director (W&M),
Standards Division.


R.W. MacLean,
Director,
Standards Division.

Reference: A-352



SD-WA-239



BOWSER GASOLINE DISPENSER
Model 585-C