



CANADA

SD-WA.253

DEPARTMENT OF TRADE AND COMMERCE
STANDARDS DIVISION

OTTAWA.....January 26, 1956.....

APPROVAL LISTING

Retail gasoline dispensing meters - Manufactured by
Erie Meter Systems, Inc., Erie 6, Pennsylvania.

Under the provisions of the Weights and Measures Act, Chapter 292, R.S.C. 1952, and Regulations thereunder (P.C. 6894), the apparatus specified and illustrated herein have been listed as approved devices and may be used in Canada in accordance with the conditions applicable.

Apparatus Listed: Computing gasoline dispensing meters with remotely located pumping unit, Models 742-16, 745-16, and 245-16, pumping unit may be the Erie submerged turbine type or the Erie chassis or cabinet type 776 series.

Capacity: Maximum capacity each dispenser 10 G.P.M.

Application: Retail gasoline trade.

Conditions: As prescribed in P.C. 6894.

Description: These devices include in their assembly the same counting head and meter as the dispensers listed on SD-WA.252 and may be serviced by a remote pumping unit equipped with a standard Erie pump and air eliminator combination or by the turbine type pump. Model 745-16 is equipped with an outside hose extension device and Model 742-16 has an inside weighted hose returning device. Model 245-16 is a side by side arrangement of two Model 745-16 meters. The meter assembly is equipped with an interlocking device and a single self cleaning protruding visiglass.

Testing: The standard tests for a meter pump shall apply.

C.S. Phillips,
Assistant Director (W&M),
Standards Division.


R. W. MacLean,
Director,
Standards Division.

Reference: 263A

**ERIE GASOLINE DISPENSER
WITH REMOTE PUMP**

80-7A-355

Model 745-16



Turbine Pump



776 Series Pump Unit

