



Consumer and  
Corporate Affairs Canada

Consommation  
et Corporations Canada

Legal Metrology

Métrieologie légale

APPROVAL No. - N° D'APPROBATION

AE-292

JUN 25 1990

**NOTICE OF APPROVAL**

Issued by statutory authority of the Director of the Legal Metrology Branch of Consumer and Corporate Affairs Canada for (category of device):

Voltage Transformer

**APPLICANT / REQUÉRANT:**

Gloucester Hydro  
4565 Bank Street  
Gloucester, Ontario  
K1G 4C1

**MODEL(S) / MODÈLE(S):**

GP-592  
(SERIAL NUMBER/Numéro de série 251773)

**NOTE:** This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the Electricity and Gas Inspection Regulations. The following is a summary of principal features only.

**AVIS D'APPROBATION**

Émis en vertu du pouvoir statutaire du directeur de la Métrieologie légale, Consommation et Corporations Canada, pour (catégorie d'appareil):

Transformateur de tension

**MANUFACTURER / FABRICANT:**

Packard Electric  
St. Catharines, Ontario

**RATING / CLASSEMENT:**

4800 - 120V

**REMARQUE:** Cette approbation ne vise que les compteurs dont la conception, la composition, la construction et le rendement sont identiques, en tout point, à ceux qui sont décrits dans la documentation reçue et pour lesquels des échantillons représentatifs ont été fournis par le requérant aux fins d'évaluation, conformément aux articles 13 et 14 du Règlement sur l'inspection de l'électricité et du gaz. Ce qui suit est une brève description de leurs principales caractéristiques.

SUMMARY DESCRIPTION:

This Approval covers one single phase, line to ground, distribution transformer, serial number 251773, to be used by Gloucester Hydro for metering on terminals X<sub>1</sub> - X<sub>2</sub>

Accuracy Class: 0.3z

Frequency: 60 Hz

Insulation Class: 8kV

APPROVAL:

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the Electricity and Gas Inspection Act. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the Electricity and Gas Inspection Act. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the said Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local inspection office of Consumer and Corporate Affairs Canada.



W.R. Virtue

Chief,  
Legal Metrology Laboratories

DESCRIPTION SOMMAIRE:

Le présent avis s'applique à un transformateur de distribution, de tension phase- terre, monophasé, numéro de série 251773, destiné à être utilisé par Gloucester Hydro pour le mesurage aux bornes X<sub>1</sub> - X<sub>2</sub>.

Classe de précision: 0.3z

Fréquence: 60 Hz

Classe d'isolement: 8 kV

APPROBATION:



La conception, la composition, la construction et le rendement du (des) type(s) de compteurs identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis sous la Loi sur l'inspection de l'électricité et du gaz, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellement, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis sous la Loi sur l'inspection de l'électricité et du gaz. Les exigences de scellement et de marquage sont définies dans les prescriptions établies en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 dudit règlement. Sauf dans le cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local de Consommation et Corporations Canada.

JUN 25 1990

Date

Chef,  
Laboratoires de la Métrologie légale

PACKARD ELECTRIC  
VOLTAGE TRANSFORMER  
TYPE - GP-592  
SERIAL #251773  
60 Hz  
VOLTAGE 4800-120  
RATIO 40:1  
ACCURACY 0.3Z  
VOLTAGE CLASS 8.0KV  
H1  H2  
  
X1 X2

**CCAC AE-292**

FOR METERING PURPOSES ONLY