



**NOTICE OF APPROVAL**

**AVIS D'APPROBATION**

Issued by statutory authority of the Minister of Industry  
for:

Émis en vertu du pouvoir statutaire du ministre de  
l'Industrie pour:

**TYPE OF DEVICE**

Instrument Transformer: current

**TYPE D'APPAREIL**

Instrument Transformer : courant

**APPLICANT**

Corimpex International  
46 Ealing Drive  
Toronto, ON, Canada  
M2L 2R5

**REQUÉRANT**

**MANUFACTURER**

Associated Engineering Co.  
101 Kuhlman Boulevard  
Versailles, Kentucky 40383  
USA

or / ou

**FABRICANT**

Kuhlman Electric Corporation  
101 Kuhlman Drive  
Crystal Spring, Mississippi 39059  
USA

**MODEL(S)/MODÈLE(S)**

COF-250  
COF-200

**RATING/CLASSEMENT**

400/800-5A  
100/200/300/400/500/600/700/800/1000-5A  
200/300/400/500/600/800/900/1000/1200-5A

Accuracy rating / Classe de précision :

See "Summary Description"/Voir "Description Sommaire

Rating Factor / Facteur de surcharge : 1.5

Frequency / Fréquence : 60 Hz

Voltage class / Catégorie de tension : 46 kV

**NOTE:** This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the *Electricity and Gas Inspection Regulations*. The following is a summary of the principal features only.

### SUMMARY DESCRIPTION:

The type COF current transformer is a porcelain post type, oil insulated, with the magnetic cores mounted in a metallic tank at the top.

### RATIO / TAP

The following ratios are approved for revenue metering:

COF-250

<b>Ratio Rapport</b>	<b>Tap Enroulement</b>	<b>Accuracy rating Classe de précision</b>
400-5A	X <sub>2</sub> - X <sub>3</sub>	0.3B1.8
800-5A	X <sub>1</sub> - X <sub>3</sub>	0.3B1.8

**REMARQUE:** Cette approbation ne vise que les compteurs dont la conception, la composition, la construction et le rendement sont identiques, en tout point, à ceux qui sont décrits dans la documentation reçue et pour lesquels des échantillons représentatifs ont été fournis par le requérant aux fins d'évaluation, conformément aux articles 13 et 14 du *Règlement sur l'inspection de l'électricité et du gaz*. Ce qui suit est une brève description de leurs principales caractéristiques.

### DESCRIPTION SOMMAIRE :

Les transformateurs de courant de type COF sont des transformateurs isolés à l'huile à support rigide en porcelaine dont les noyaux magnétiques sont installés dans un réservoir métallique placé au haut du support.

### RAPPORT / ENROULEMENT

Les rapports suivants sont approuvés aux fins de facturation :

COF-250

<b>Ratio Rapport</b>	<b>Tap Enroulement</b>	<b>Accuracy rating Classe de précision</b>
100-5A	X <sub>4</sub> - X <sub>5</sub>	0.3B0.1
200-5A	X <sub>3</sub> - X <sub>5</sub>	0.3B0.5
300-5A	X <sub>1</sub> - X <sub>2</sub>	0.3B1.8
400-5A	X <sub>2</sub> - X <sub>3</sub>	0.3B1.8
500-5A	X <sub>2</sub> - X <sub>4</sub>	0.3B1.8
600-5A	X <sub>2</sub> - X <sub>5</sub>	0.3B1.8
700-5A	X <sub>1</sub> - X <sub>3</sub>	0.3B1.8
800-5A	X <sub>1</sub> - X <sub>4</sub>	0.3B1.8
1000-5A	X <sub>1</sub> - X <sub>5</sub>	0.3B1.8

COF-250  
COF-200

<b>Ratio Rapport</b>	<b>Tap Enroulement</b>	<b>Accuracy rating Classe de précision</b>
200-5A	X <sub>4</sub> - X <sub>5</sub>	0.3B0.5
300-5A	X <sub>3</sub> - X <sub>5</sub>	0.3B1.8
400-5A	X <sub>1</sub> - X <sub>2</sub>	0.3B1.8
500-5A	X <sub>2</sub> - X <sub>3</sub>	0.3B1.8
600-5A	X <sub>2</sub> - X <sub>4</sub>	0.3B1.8
800-5A	X <sub>2</sub> - X <sub>5</sub>	0.3B1.8
900-5A	X <sub>1</sub> - X <sub>3</sub>	0.3B1.8
1000-5A	X <sub>1</sub> - X <sub>4</sub>	0.3B1.8
1200-5A	X <sub>1</sub> - X <sub>5</sub>	0.3B1.8

**REVISION****Rev. 1**

The purpose of revision 1 was to include additional ratios (100/200/300/400/500/600/700/800/1000-5A).

**Rev. 2**

The purpose of revision 2 was to include additional ratios (200/300/400/500/800/900/1000/1200-5A).

**Rev. 3**

The purpose of revision 3 is to include additional model COF-200.

**EVALUATED BY**

David Lau, Rev. 1 and 3  
Complex Approvals Examiner  
Tel: (613) 952-0647  
Fax: (613) 952-1754

**RÉVISION****Rév. 1**

La révision 1 visait à ajouter des rapports additionnels (100/200/300/400/500/600/700/800/1000-5A).

**Rév. 2**

La révision 2 visait à ajouter des rapports additionnels (200/300/400/500/800/900/1000/1200-5A).

**Rév 3**


La révision 3 visait à ajouter des modèle additionels COF-200.

**ÉVALUÉ PAR**

David Lau, Rév. 1 et 3  
Examineur d'approbations complexes  
Tél: (613) 952-0647  
Fax: (613) 952-1754



**COF-250**



**APPROVAL:**

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local office of Measurement Canada.

Original signed by:

Vuong Nguyen  
Senior Engineer – Electricity Measurement  
Engineering and Laboratory Services Directorate

**APPROBATION :**

La conception, la composition, la construction et le rendement du(des) type(s) de compteur(s) identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellage, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*. Les exigences de scellage et de marquage sont définies dans les prescriptions établis en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 dudit règlement. En plus de cette approbation et sauf dans les cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local de Mesures Canada.

Copie authentique signée par :

Vuong Nguyen  
Ingénieur principal – Mesure de l'électricité  
Direction de l'ingénierie et des services de laboratoire

Date: **2004-09-02**

Web Site Address / Adresse du site Internet:  
<http://mc.ic.gc.ca>