



SEP 11 1997

NOTICE OF APPROVAL

AVIS D'APPROBATION

Issued by statutory authority of the Minister of Industry
 for:

Émis en vertu du pouvoir statutaire du ministre de
 l'Industrie pour:

TYPE OF DEVICE

TYPE D'APPAREIL

Instrument transformer: Voltage

Transformateur de mesure: tension

APPLICANT

REQUÉRANT

Corimpex International Inc. and/et
 46 Ealing Drive
 Toronto, Ontario
 M2L 2R5

Kuhlman Electric Corp.
 101 Kuhlman Drive
 Crystal Spring, Mississippi, 39059
 USA

MANUFACTURER

FABRICANT

Associated Engineering Company
 Versailles, Kentucky
 USA
 28106

MODEL(S) / MODÈLE(S)

RATING / CLASSEMENT

SPOF-110

14400 - 120 - 120 V
 14400 - 120 V
 Accuracy rating / Classe de précision: 0.3WXYZ,ZZ
 Frequency / Fréquence: 60 Hz
 Voltage class / Tension nominale: 15 kV

NOTE: This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the Electricity and Gas Inspection Regulations. The following is a summary of the principal features only.

REMARQUE: Cette approbation ne vise que les compteurs dont la conception, la composition, la construction et le rendement sont identiques, en tout point, à ceux qui sont décrits dans la documentation reçue et pour lesquels des échantillons représentatifs ont été fournis par le requérant aux fins d'évaluation, conformément aux articles 13 et 14 du Règlement sur l'inspection de l'électricité et du gaz. Ce qui suit est une brève description de leurs principales caractéristiques.

SUMMARY DESCRIPTION:**DESCRIPTION SOMMAIRE:****DESCRIPTION****DESCRIPTION**

This Double Bushing oil filled voltage transformer is designed for outdoor use.

Le transformateur de tension à double traversée, rempli à l'huile, est conçu pour un usage extérieur.

REVISION 1**RÉVISION 1**

The purpose of this revision is to include one additional ratio (14400-120 V).

Le but de cette révision est d'inclure un rapport additionnel (14400-120 V).


EVALUATED BY**ÉVALUÉ PAR**

David Lau
Approvals Examiner
Tel: (613) 952-0647
Fax: (613) 952-1754

David Lau
Examineur des approbations
Tél: (613) 952-0647
Fax: (613) 952-1754

SUMMARY DESCRIPTION: Cont'd


DESCRIPTION SOMMAIRE: Suite



APPROVAL:

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the Electricity and Gas Inspection Act. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the Electricity and Gas Inspection Act. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local inspection office of Industry Canada.



For/pour:

René Magnan, P.Eng.
Acting Director
Approval Services Laboratory

APPROBATION:

La conception, la composition, la construction et le rendement du(des) type(s) de compteurs identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis aux termes de la Loi sur l'inspection de l'électricité et du gaz, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellement, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis aux termes de la Loi sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 dudit règlement. Sauf dans le cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local d'Industrie Canada.

René Magnan, ing.
Directeur intérimaire
Laboratoire des services d'approbation

Date: SEP 11 1997