



**NOTICE OF APPROVAL**

**AVIS D'APPROBATION**

Issued by statutory authority of the Minister of Industry  
for:

Émis en vertu du pouvoir statutaire du ministre de  
l'Industrie pour:

**TYPE OF DEVICE**

**TYPE D'APPAREIL**

Instrument Transformer: Current

Transformateur de mesure: courant

**APPLICANT**

**REQUÉRANT**

ABB Power T&D Co. Ltd.  
P.O. Box 687  
Pinetops, North Carolina, 27864  
USA

**MANUFACTURER**

**FABRICANT**

ABB Power T&D Co. Ltd.  
P.O. Box 687  
Pinetops, North Carolina, 27864  
USA

**MODEL(S)/MODÈLE(S)**

**RATING/ CLASSEMENT**

KOTD-200  
Style# 9629A31G08  
Style# 923A177G08  
Style# CSA923A177G15  
Style# 923A171G09

Accuracy Class/Classe de précision:  
See "Summary Description / Voir description sommaire"  
Rating Factor / Facteur de surcharge: 1.0, 1.5  
Frequency / Fréquence: 60 Hz  
Voltage class / Catégorie de tension: 70 kV

**NOTE:** This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the Electricity and Gas Inspection Regulations. The following is a summary of the principal features only.

### SUMMARY DESCRIPTION:

The KOTD-200 is a current transformer which is completely moulded butyl rubber and is intended for outdoor use.

### RATIO AND TAP

The following ratios and taps are approved for revenue metering:

**REMARQUE:** Cette approbation ne vise que les compteurs dont la conception, la composition, la construction et le rendement sont identiques, en tout point, à ceux qui sont décrits dans la documentation reçue et pour lesquels des échantillons représentatifs ont été fournis par le requérant aux fins d'évaluation, conformément aux articles 13 et 14 du Règlement sur l'inspection de l'électricité et du gaz. Ce qui suit est une brève description de leurs principales caractéristiques.

### DESCRIPTION SOMMAIRE:

Le KOTD-200 est un transformateur de courant en caoutchouc butyle moulé et destiné à une utilisation extérieure.


### RAPPORT ET ENROULEMENT

Les rapports et enroulements suivant sont approuvés aux fins de facturations.

Model Modèle	Ratio Rapport	Tap Enroulement	Accuracy class Classe de précision
9629A31G08	1200-5A	X <sub>1</sub> - X <sub>5</sub>	0.3B1.8
CSA923A177G15	2000-5A	X <sub>1</sub> - X <sub>5</sub>	0.3B1.8
923A177G08	800-5A	X <sub>1</sub> - X <sub>4</sub>	0.3B1.8
	600-5A	X <sub>2</sub> - X <sub>4</sub>	0.3B0.9
	300-5A	X <sub>1</sub> - X <sub>3</sub>	0.3B0.9
923A171G09	1600-5A	X <sub>1</sub> - X <sub>5</sub>	0.3B1.8
	1300-5A	X <sub>2</sub> - X <sub>5</sub>	0.3B1.8
	1200-5A	X <sub>1</sub> - X <sub>4</sub>	0.3B1.8
	1000-5A	X <sub>3</sub> - X <sub>5</sub>	0.3B1.8
	900-5A	X <sub>2</sub> - X <sub>4</sub>	0.3B1.8
	600-5A	X <sub>1</sub> - X <sub>3</sub>	0.3B1.8
	400-5A	X <sub>4</sub> - X <sub>5</sub>	0.3B0.5

**NAMEPLATE AND MARKINGS**

**PLAQUE SIGNALÉTIQUE ET MARQUAGES**



**REVISION****Original**                      **Issued Date: 1997-04-17****Rev. 1**                              **Issued Date: 1999-01-07**

The purpose of this revision is to add a new style 923A177G08.

**Rev. 2**                              **Issued Date: 2004-01-13**

The purpose of this revision is to add a new Style # CSA923A177G15, and correction of editorials.

**Rev. 3**

The purpose of revision 3 is to add a new style 923A171G09.

**EVALUATED BY**

David Lau, Rev. 1 , 2 & 3  
Complex Approvals Examiner  
Tel: (613) 952-0647  
Fax: (613) 952-1754

**RÉVISION****Originale**                      **Date d'émission: 1997-04-17****Rev. 1**                              **Date d'émission: 1999-01-07**

Cette révision vise à ajouter un nouveau # de style 923A177G08.

**Rév. 2**                              **Date d'émission: 2004-01-13**

Cette révision vise à ajouter un nouveau # de style CSA923A177G15, et correction éditorial.

**Rév. 3**

La révision 3 vise à ajouter un nouveau # de style 923A171G09.

**ÉVALUÉ PAR**

David Lau, Rév. 1 , Rév. 2 et Rév.3  
Examinateur d'approbations complexes  
Tél: (613) 952-0647  
Fax: (613) 952-1754

**APPROVAL:**

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local office of Measurement Canada.

Original signed by:

Vuong Nguyen  
Senior Engineer – Electricity Measurement  
Engineering and Laboratory Services Directorate

**APPROBATION :**

La conception, la composition, la construction et le rendement du(des) type(s) de compteur(s) identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellage, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*. Les exigences de scellage et de marquage sont définies dans les prescriptions établis en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 dudit règlement. En plus de cette approbation et sauf dans les cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local de Mesures Canada.

Copie authentique signée par :

Vuong Nguyen  
Ingénieur principal – Mesure de l'électricité  
Direction de l'ingénierie et des services de laboratoire

Date: **2006-02-17**

Web Site Address / Adresse du site Internet:  
<http://mc.ic.gc.ca>