

NOTICE OF APPROVAL

Issued by statutory authority of the Minister of Industry
for:

AVIS D'APPROBATION

Émis en vertu du pouvoir statutaire du ministre de
l'Industrie pour:

TYPE OF DEVICE

Instrument Transformer: Current

TYPE D'APPAREIL

Transformateur de mesure: courant

APPLICANT

REQUÉRANT

Polycast Industrial Products
965 Sherwin Road
Winnipeg, Manitoba
R3H 0T8

MANUFACTURER

FABRICANT

Polycast Industrial Products
965 Sherwin Road
Winnipeg, Manitoba
R3H 0T8

MODEL(S)/MODÈLE(S)

RATING/ CLASSEMENT

134-035-95A

3200/2400/1600/400-5A

Accuracy class / Classe de précision:

See "Description Summary/Voir description sommaire"

Rating factor / Facteur de surcharge: 1.33

Frequency / Fréquence: 60 Hz

Voltage class / Catégorie de tension: 15 kV

NOTE: This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the Electricity and Gas Inspection Regulations. The following is a summary of the principal features only.

SUMMARY DESCRIPTION:

The 134-035-95A is a window type current instrument transformer intended for indoor use.

RATIO / TAP

The following ratios are approved for revenue metering:

Ratio Rapport	Tap Enroulement	Accuracy class Classe de précision
400-5A	X ₁ -X ₂	0.3B0.5
800-5A	X ₃ -X ₄	0.3B0.9
1200-5A	X ₂ -X ₃	0.3B0.9
1600-5A	X ₁ -X ₃	0.3B0.9
2000-5A	X ₂ -X ₄	0.3B0.9
2400-5A	X ₁ -X ₄	0.3B0.9
2800-5A	X ₂ -X ₅	0.3B0.9
3200-5A	X ₁ -X ₅	0.3B0.9

EVALUATED BY

David Lau
Complex Approvals Examiner
Tel: (613) 952-0647
Fax: (613) 952-1754

ÉVALUÉ PAR

David Lau
Examinateur d'approbations complexes
Tél: (613) 952-0647
Fax: (613) 952-1754

NAMEPLATES AND MARKINGS**PLAQUES SIGNALÉTIQUES ET MARQUAGE**

CURRENT TRANSFORMER			
CSA CI3 / ANSI C57.13			
TYPE	PCW25 Series	ACCUR.	0.3B0.5 @ 400-5
ID. NO.	134-035-95A		0.3B0.9 @ 800-5
INS. CL.	15 kV		0.3B0.9 @ 1200-5
IMP. LEV.	110 kV		0.3B0.9 @ 1600-5
RAT. FACT.	1.33		0.3B0.9 @ 2000-5
IC APR #			0.3B0.9 @ 2400-5
			0.3B0.9 @ 2800-5
			0.3B0.9 @ 3200-5
		PRI. A.	3200/2400/1600/400
		SEC. A.	5
		CYCLES	60 Hz.
		SER. NO.	46153 - 1
X1-X2	400-5	X1-X3	1600-5
X1-X4	2400-5	X1-X5	3200-5

 **POLYCAST**
INTERNATIONAL 

965 Sherwin Rd.
Winnipeg, MB
R3K 0T6
(204) 632-5428



APPROVAL:

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local office of Measurement Canada.

APPROBATION :

La conception, la composition, la construction et le rendement du(des) type(s) de compteur(s) identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellage, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*. Les exigences de scellage et de marquage sont définies dans les prescriptions établis en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 dudit règlement. En plus de cette approbation et sauf dans les cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local de Mesures Canada.

Original signed by Claude Renaud for :

Vuong Nguyen
Senior Engineer – Electricity Measurement
Engineering and Laboratory Services Directorate

Copie authentique signée par Claude Renaud pour :

Vuong Nguyen
Ingénieur principal – Mesure de l'électricité
Direction de l'ingénierie et des services de laboratoire

Date: **2005-11-02**

Web Site Address / Adresse du site Internet:
<http://mc.ic.gc.ca>