



Mesures Canada

NOTICE OF APPROVAL

Issued by statutory authority of the Minister of Industry for:

AVIS D'APPROBATION

Émis en vertu du pouvoir statutaire du ministre de l'Industrie pour:

TYPE OF DEVICE

Instrument Transformer: Voltage and Current

TYPE D'APPAREIL

Transformateur de mesure: tension et courant

APPLICANT

REQUÉRANT

ABB Inc.
8555 Trans Canada Highway
Saint Laurent
Quebec H4S 1Z6

MANUFACTURER

FABRICANT

ABB Sweden (Ludvika)
High Voltage Products, PPHV
Lyviksvägen 4, Ludvika
771 80
Dalarna
Sweden

MODEL(S)/MODÈLE(S)

RATING/ CLASSEMENT

EMF 72

40250-115/67V

Accuracy class / Classe de précision: 0.3WXYZ
Frequency / Fréquence: 60 Hz
Voltage class / Catégorie de tension: 72.5 kV

NOTE: This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the Electricity and Gas Inspection Regulations. The following is a summary of the principal features only.

SUMMARY DESCRIPTION:

This EMF-72 is a post-type combined voltage and current transformer. It is designed for outdoor use.

RATIO / TAP

The following ratios are approved for revenue metering:

Voltage/Tension	Ratio Rapport	Tap Enroulement	Accuracy class Classe de précision	Voltage Class Catégorie de tension
40250-115/67V	40250-115V	Y ₁ - Y ₃	0.3 WXYZ	72.5 kV
	40250-115V	X ₁ - X ₃	0.3 WXYZ	72.5 kV

EVALUATED BY

Michael Rozeboom,
Legal Metrologist

ÉVALUÉ PAR

Michael Rozeboom,
Métrologiste légal

APPROVAL No. - N° D'APPROBATION

AE-1700

NAMEPLATE AND MARKINGS

PLAQUE SIGNALÉTIQUE ET MARQUAGE

ABB	CE	ABB AB	Made in Sweden
Voltage transformer		Type	EMF 72 Production year yyyy
Serial number	1HSE nnnnnnn	Standard	CAN3-C13
Insulation level	140 / 350 kV	Frequency	60 Hz
Rated primary voltage	40250 V	Temperature range	-40 – +40 °C
Highest voltage for equipment	72,5 kV	Total mass	310 kg
Nova Scotia Power PO no. 205612	MFR. with <2ppm PCB substance	IC approval no.	AExxxxx

APPROVAL No. - N° D'APPROBATION

AE-1700



APPROVAL:

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local office of Measurement Canada.

APPROBATION :

La conception, la composition, la construction et le rendement du(des) type(s) de compteur(s) identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellage, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*. Les exigences de scellage et de marquage sont définies dans les prescriptions établis en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 dudit règlement. En plus de cette approbation et sauf dans les cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local de Mesures Canada.

ORIGINAL COPY SIGNED BY:

Vuong Nguyen
Senior Engineer – Electricity Measurement
Engineering and Laboratory Services Directorate

COPIE AUTHENTIQUE SIGNÉE PAR:

Vuong Nguyen
Ingénieur principal – Mesure de l'électricité
Direction de l'ingénierie et des services de laboratoire

Date: **2010-01-22**

Web Site Address / Adresse du site Internet:
<http://mc.ic.gc.ca>