



Mesures Canada

NOTICE OF APPROVAL

Issued by statutory authority of the Minister of Industry for:

Émis en vertu du pouvoir statutaire du ministre de l'Industrie pour:

TYPE OF DEVICE

Instrument Transformer: Voltage

TYPE D'APPAREIL

Transformateur de mesure: tension

APPLICANT

REQUÉRANT

Trench Italia S. R. L.
Strada Curagnata, 37
17014 Cairo Montenotte (SV)
Italy

MANUFACTURER

FABRICANT

Trench Italia S. R. L.
Strada Curagnata, 37
17014 Cairo Montenotte (SV)
Italy

MODEL(S)/MODÈLE(S)

SUD145/S82

RATING/ CLASSEMENT

80500 - 230 - 115V

Accuracy class / Classe de précision: 0.3 WXYZ

Rating factor / Facteur de surcharge : 1.5 Un 30s

Frequency / Fréquence: 60 Hz

Voltage class / Catégorie de tension: 145 kV

NOTE: This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the Electricity and Gas Inspection Regulations. The following is a summary of the principal features only.

SUMMARY DESCRIPTION:

The SUD145/S82 is a three phase, SF₆ gas filled, duct type voltage transformer. It is designed for outdoor use.

RATIO AND TAP

The following ratio is approved for revenue metering:

| Ratio Rapport | Tap Borne | Accuracy Class Classe de précision | Rating Factor Facteur de surcharge |
|--------------------------|--------------------------------|---|---|
| 80500 - 115V | X ₂ -X ₃ | 0.3WXYZ | 1.5 Un 30s |

EVALUATED BY


Michael Rozeboom
Legal Metrologist

ÉVALUÉ PAR

Michael Rozeboom
Métrologiste légal

NAMEPLATE AND MARKINGS**PLAQUE SIGNALÉTIQUE ET MARQUAGES**

| Voltagetransformer | | •I - H2 | •II - H2 | •III - H2 |
|---|------|-----------------|--|-------------------------------------|
| V | | 80500 | 80500 | 80500 |
| | | •X1; •X2 - X3 | •X1; •X2 - X3 | •X1; •X2 - X3 |
| SUD 145/S82 | | V | 230-115 | 230-115 |
| 145/315/650 | kV | VA | 200 | 200 |
| E | 60 | CL | 0.3WXMYZ | 0.3WXMYZ |
| 1,5 U _N | 30 s | A | | |
| 235 kV / 102 Hz | | | | |
| ANSI | | SF ₆ | MIN. OPERATING PRESSURE ADM. SERVICE OVERPRESSURE | 5.0 bar rel. (20°C) 8.0 bar rel. |
| AE-XXXX | | | | |
| TRENCH GERMANY GMBH, D-96050 BAMBERG | | | | |
| Total Weight | kg | 490 | SF ₆ WEIGHT FOR TRANSPORT | 2.0 kg |
| | | | | MADE IN GERMANY 230990 |



APPROVAL:

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the Electricity and Gas Inspection Act. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the Electricity and Gas Inspection Act. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local office of Measurement Canada.

APPROBATION:

La conception, la composition, la construction et le rendement du(des) type(s) de compteur(s) identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis aux termes de la Loi sur l'inspection de l'électricité et du gaz, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellage, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis aux termes de la Loi sur l'inspection de l'électricité et du gaz. Les exigences de scellage et de marquage sont définies dans les prescriptions établies en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 du dit règlement. En plus de cette approbation et sauf dans les cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local de Mesures Canada.

ORIGINAL COPY SIGNED BY:

Vuong Nguyen
Senior Engineer – Electricity Measurement
Engineering and Laboratory Services Directorate

COPIE AUTHENTIQUE SIGNÉE PAR:

Vuong Nguyen
Ingénieur principal – Mesure de l'électricité
Direction de l'ingénierie et des services de laboratoire

Date: **2010-02-19**

Web Site Address / Adresse du site Internet:
<http://mc.ic.gc.ca>