



Mesures Canada

**NOTICE OF APPROVAL**

**AVIS D'APPROBATION**

Issued by statutory authority of the Minister of Industry for:

Émis en vertu du pouvoir statutaire du ministre de l'Industrie pour:

**TYPE OF DEVICE**

**TYPE D'APPAREIL**

Instrument Transformer: Current

Transformateur de mesure: courant

**APPLICANT**

**REQUÉRANT**

CT-eTECH Co., Ltd.,  
652 Moonhyeong-ri,  
Opo-eup, Kwangju-si  
Kyeonggi-do  
Korea 464-924

**MANUFACTURER**

**FABRICANT**

Hyundai Heavy Industries Co., Ltd.  
Transformer Design Dept.,  
Jeonha-dong, Dong-gu  
Ulsan  
Korea 687-792

**MODEL(S)/MODÈLE(S)**

**RATING/ CLASSEMENT**

BCT  
CB-6886

2000/1500/1200/400-5A  
Accuracy class / Classe de précision: 0.3B1.8  
Rating factor / Facteur de surcharge: 1.5  
Frequency / Fréquence: 60 Hz  
Voltage class / Catégorie de tension: 0.7 kV

**NOTE:** This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the Electricity and Gas Inspection Regulations. The following is a summary of the principal features only.

### SUMMARY DESCRIPTION:

The model CB-6886 is a bushing current transformer.

### RATIO / TAP

The following ratio is approved for revenue metering:

Ratio Rapport	Tap Enroulement	Accuracy class Classe de précision	Rating Factor Facteur de surcharge
1200-5A	X <sub>1</sub> -X <sub>3</sub>	0.3B1.8	1.5

### EVALUATED BY

Michael Rozeboom  
Legal Metrologist

### ÉVALUÉ PAR

Michael Rozeboom  
Métrologiste légal

### NAMEPLATE AND MARKINGS

### PLAQUE SIGNALÉTIQUE ET MARQUAGES

CURRENT TRANSFORMER				RATIO(A)	SEC.TAPS	SUBTRACTIVE POLARITY H1 ——— PRI ———> H2 SEC
TYPE	CB-6886	CAN3-C13-M83		2000/5	X1-X5	
CLASS	2.5L400 & 0.3B1.8 @ 1200/5A			1500/5	X1-X4	
BURDEN	100&45VA	60 Hz	59 kg	1200/5	X1-X3	
SER. NO	IDB1491	DATE	2009. 04	400/5	X1-X2	
PROJ. NO	80835TID008		PROJ.NAME	SNC / Altalink S.E. Project		
R.F.=1.5 / APPROVAL NO. :				HYUNDAI HEAVY INDUSTRIES CO.,LTD.		

**REMARQUE:** Cette approbation ne vise que les compteurs dont la conception, la composition, la construction et le rendement sont identiques, en tout point, à ceux qui sont décrits dans la documentation reçue et pour lesquels des échantillons représentatifs ont été fournis par le requérant aux fins d'évaluation, conformément aux articles 13 et 14 du Règlement sur l'inspection de l'électricité et du gaz. Ce qui suit est une brève description de leurs principales caractéristiques.

### DESCRIPTION SOMMAIRE:

Le modèle CB-6886 est un transformateur de courant pour traversée.

### RAPPORT / ENROULEMENT

Le rapport suivant est approuvé aux fins de facturation:

**APPROVAL:**

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local office of Measurement Canada.

**ORIGINAL COPY SIGNED BY:**

Vuong Nguyen  
Senior Engineer – Electricity Measurement  
Engineering and Laboratory Services Directorate

**APPROBATION :**

La conception, la composition, la construction et le rendement du(des) type(s) de compteur(s) identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellage, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*. Les exigences de scellage et de marquage sont définies dans les prescriptions établis en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 dudit règlement. En plus de cette approbation et sauf dans les cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local de Mesures Canada.

**COPIE AUTHENTIQUE SIGNÉE PAR:**

Vuong Nguyen  
Ingénieur principal – Mesure de l'électricité  
Direction de l'ingénierie et des services de laboratoire

Date: **2010-05-31**

Web Site Address / Adresse du site Internet:  
<http://mc.ic.gc.ca>