



Measurement Canada
An agency of Industry Canada

Mesures Canada
Un organisme d'Industrie Canada

MAL No. - N° De LAM

MAL-E53

Date: December 4, 2002

File number: 06565-AP-AE-02-0117

MODIFICATION ACCEPTANCE LETTER (MAL) FOR Approved Meters and Devices

Type of Device

Electricity Meter: Energy
Multi Customer Metering System

Purpose

The purpose of this letter is to convey details of modifications to meters which have previously received approval of type recognition from An agency of Industry Canada. These modifications have been evaluated by the Approval Services Laboratory in accordance with national requirements and shall be considered to be included within the scope of the originally issued Notices of Approval specified in this document and any subsequent revisions to these Notices of Approval.

Scope

The modifications described in this letter affect meters identified in the following Notices of Approval:

Approval Numbers

AE-1183

Applicant

Stratacon
41 Courtland Avenue, Suite 9
Vaughan, Ontario
L4K 3T3

Description of Modifications

The pulse output for testing has a Kp value of 10.0 W·h

Original signed by:
Claude Renaud
Approvals Technical Coordinator
Electricity Measurement Discipline



Measurement Canada
An agency of Industry Canada

Mesures Canada
Un organisme d'Industry Canada

MAL No. - N° De LAM

MAL-E53

Date: 4 décembre 2002

Dossier: 06565-AP-AE-02-0117

LETTRE D'ACCEPTATION DE MODIFICATION (LAM)

pour
Compteurs et Appareils Approuvés

Type d'Appareil

Compteurs Électrique: énergie
Compteur à client multiple

Objet

La présente lettre vise à expliquer les détails des modifications apportées aux compteurs dont le type a déjà été approuvé par Mesures Canada. Ces modifications ont été évaluées par le Laboratoire des services d'approbation en conformité aux exigences nationales et doivent être considérées comme faisant partie de la portée des avis d'approbation d'origine énumérés dans le présent document et de toutes leurs révisions subséquentes.

Portée

Les modifications décrites dans la présente lettre s'appliquent aux compteurs visés par les avis d'approbation suivant:

Numéros d'approbation

AE-1183

Requérant

Stratacon
41 Courtland Avenue, Suite 9
Vaughan, Ontario
L4K 3T3

Descriptions des modifications

Les impulsion de sortie, aux fins d'essais, ont une valeur de 10,0 W•h

Copie authentique signée par:
Claude Renaud
Coordonnateur en technologie, approbations
Discipline de l'électricité