



Measurement Canada  
An Agency of Industry Canada

Mesures Canada  
Un organisme d'Industrie Canada

MAL No. - N° De LAM

**MAL-E171**

Date: 2008/10/20

File number: 26681-AP-AE-08-0128

## **MODIFICATION ACCEPTANCE LETTER (MAL) FOR Approved Meters and Devices**

### **Type of Device**

Electricity Meter: Energy and Demand

### **Purpose**

The purpose of this letter is to convey details of modifications to meters which have previously received approval of type recognition from An agency of Industry Canada. These modifications have been evaluated by the Approval Services Laboratory in accordance with national requirements and shall be considered to be included within the scope of the originally issued Notices of Approval specified in this document and any subsequent revisions to these Notices of Approval.

### **Scope**

The modifications described in this letter affect meters identified in the following Notices of Approval:

### **Approval Numbers**

AE-1559

### **Applicant**

Landis + Gyr Inc.  
2800 Duncan Road  
Lafayette, IN  
47904

### **Description of Modifications**

The firmware of the TS2 module approved to be used with the FOCUS II meter passed from the version 19 to version 20.

Original copy signed by:

Isabelle Tremblay  
Manager– Electricity Measurement



Date: 2008/10/20

Dossier: 26681-AP-AE-08-0128

**LETTRE D'ACCEPTATION DE MODIFICATION (LAM)**  
**pour**  
**Compteurs et Appareils Approuvés**

**Type d'Appareil**

Compteurs Électrique: Énergie et puissance

**Objet**

La présente lettre vise à expliquer les détails des modifications apportées aux compteurs dont le type a déjà été approuvé par Mesures Canada. Ces modifications ont été évaluées par le Laboratoire des services d'approbation en conformité aux exigences nationales et doivent être considérées comme faisant partie de la portée des avis d'approbation d'origine énumérés dans le présent document et de toutes leurs révisions subséquentes.

**Portée**

Les modifications décrites dans la présente lettre s'appliquent aux compteurs visés par les avis d'approbation suivant:

**Numéros d'approbation**

AE-1559

**Requérant**

Landis + Gyr Inc.  
2800 Duncan Road  
Lafayette, IN  
47904

**Descriptions des modifications**

Le microprogramme du module TS2 approuvé pour être utilisé avec le compteur FOCUS II a passé de la version 19 à la version 20.

Copie authentique signée par :

Isabelle Tremblay  
Gestionnaire – Mesure de l'électricité