



Date: 2010/09/27

File number: 26681-AP-AE-10-0116

MODIFICATION ACCEPTANCE LETTER (MAL) FOR Approved Meters and Devices

Type of Device

Electricity Meter: Energy

Purpose

The purpose of this letter is to convey details of modifications to meters which have previously received approval of type recognition from An Agency of Industry Canada. These modifications have been evaluated by the Approval Services Laboratory in accordance with national requirements and shall be considered to be included within the scope of the originally issued Notices of Approval specified in this document and any subsequent revisions to these Notices of Approval.

Scope

The modifications described in this letter affect meters identified in the following Notices of Approval:

Approval Numbers

AE-1636

Applicant

Meramec Electrical Products Co. Inc.
#1 Industrial Drive
Cuba, MO, 65453
USA

Description of Modifications

Additional protection class ratings.

		Part No: D101059H3M	I.C. APPROVAL#: AE-1636	H
Type	BCT.	AC CL: 2.5L800 @2000-52.5L400 @1200-52.5L400 @800-5, & 0.3B1.8 @2000*500/1200/800-5		
MFG Date	10-10	Ratio: 2000/1500/1200/400-5		H
No.	01	Freq: 60HZ		
		FF: 2.0		

ORIGINAL COPY SIGNED BY:

Isabelle Tremblay
Laboratory Manager - Electricity Measurement



Date: 2010/09/27

Dossier: 26681-AP-AE-10-0116

LETTRE D'ACCEPTATION DE MODIFICATION (LAM)
pour
Compteurs et Appareils Approuvés

Type d'Appareil
Compteurs Électrique: Énergie


Objet
La présente lettre vise à expliquer les détails des modifications apportées aux compteurs dont le type a déjà été approuvé par Mesures Canada. Ces modifications ont été évaluées par le Laboratoire des services d'approbation en conformité aux exigences nationales et doivent être considérées comme faisant partie de la portée des avis d'approbation d'origine énumérés dans le présent document et de toutes leurs révisions subséquentes.

Portée
Les modifications décrites dans la présente lettre s'appliquent aux compteurs visés par les avis d'approbation suivant:

Numéros d'approbation
AE-1636

Requérant
Meramec Electrical Products Co. Inc.
#1 Industrial Drive
Cuba, MO, 65453
USA

Descriptions des modifications
Addition de facteurs de classe

		Part No: D101059H63M	I.C. APPROVAL #: AE-1636	H
		AC CL: 2.5L800 @2000-52.5L400 @1200-52.5L400 @800-5, & 0.3B1.8 @2000/1500/1200/800-5		
Type:	B.C.T.	Ratio:	2000/1500/1200/400-5	
MFG Date:	10-10	Freq:	60 HZ	H
No.:	01	RF:	2.0	

COPIE AUTHENTIQUE SIGNÉE PAR:

Isabelle Tremblay
Gestionnaire de laboratoire - Mesure de l'électricité