



Date: 2010-11-26

File number: 26681-AP-AE-10-0142

## **MODIFICATION ACCEPTANCE LETTER (MAL) FOR Approved Meters and Devices**

### **Type of Device**

Electricity Meter: Energy and Demand

### **Purpose**

The purpose of this letter is to convey details of modifications to meters which have previously received approval of type recognition from An Agency of Industry Canada. These modifications have been evaluated by the Approval Services Laboratory in accordance with national requirements and shall be considered to be included within the scope of the originally issued Notices of Approval specified in this document and any subsequent revisions to these Notices of Approval.

### **Scope**

The modifications described in this letter affect meters identified in the following Notices of Approval:

### **Approval Numbers**

AE-1579

### **Applicant**

Elster Metering  
1100 Walker's Line, Suite 101  
Burlington, Ontario  
L7N 2G3

### **Description of Modifications**

The Firmware on the Zigbee option board has been modified. The new version 5.00 has a Zigbee SmartEnergy Profile that is compatible with the Zigbee SmartEnergy standard.

### **Original copy signed by:**

Isabelle Tremblay  
Laboratory Manager - Electricity Measurement



Date: 2010-11-26

Dossier: 26681-AP-AE-10-0142

## **LETTRE D'ACCEPTATION DE MODIFICATION (LAM)** **pour** **Compteurs et Appareils Approuvés**

### **Type d'Appareil**

Compteurs Électrique: Énergie et de puissance

### **Objet**

La présente lettre vise à expliquer les détails des modifications apportées aux compteurs dont le type a déjà été approuvé par Mesures Canada. Ces modifications ont été évaluées par le Laboratoire des services d'approbation en conformité aux exigences nationales et doivent être considérées comme faisant partie de la portée des avis d'approbation d'origine énumérés dans le présent document et de toutes leurs révisions subséquentes.

### **Portée**

Les modifications décrites dans la présente lettre s'appliquent aux compteurs visés par les avis d'approbation suivant:

### **Numéros d'approbation**

AE-1579

### **Requérant**

Elster Metering  
1100 Walker's Line, Suite 101  
Burlington, Ontario  
L7N 2G3

### **Descriptions des modifications**

Le microprogramme de la carte de communication optionnelle Zigbee a été modifié. La nouvelle version 5.00 a un profil de Zigbee SmartEnergy qui est compatible avec le standard de Zigbee SmartEnergy.

### **Copie authentique signée par:**

Isabelle Tremblay  
Gestionnaire de laboratoire - Mesure de l'électricité