



Measurement Canada
An Agency of Industry Canada

Mesures Canada
Un organisme d'Industrie Canada

MAL No. - N° De LAM
MAL-E285

Date: 2011-11-28

File number: 26681-AP-AE-11-0145

MODIFICATION ACCEPTANCE LETTER (MAL) FOR Approved Meters and Devices

Type of Device

Electricity Meter: Energy

Purpose

The purpose of this letter is to convey details of modifications to meters which have previously received approval of type recognition from An Agency of Industry Canada. These modifications have been evaluated by the Approval Services Laboratory in accordance with national requirements and shall be considered to be included within the scope of the originally issued Notices of Approval specified in this document and any subsequent revisions to these Notices of Approval.

Scope

The modifications described in this letter affect meters identified in the following Notices of Approval:

Approval Numbers


AE-1631

Applicant

Itron Canada, Inc.
2624 Dunwin Dr, Unit 4
Mississauga, Ontario
Canada, L5L-3T5

Description of Modifications

The new meter base for forms 1S, 2S and 12S Network of the OpenWay CENTRON single phase meter has been approved. The new base does not have a blank plug which was used to cover the potential link window. The window will be molded into the base.



Original copy signed by:

Isabelle Tremblay
Laboratory Manager - Electricity Measurement



Measurement Canada
An Agency of Industry Canada

Mesures Canada
Un organisme d'Industry Canada

MAL No. - N° De LAM
MAL-E285

Date: 2011-11-28

Dossier: 26681-AP-AE-11-0145

LETTRE D'ACCEPTATION DE MODIFICATION (LAM) **pour** **Compteurs et Appareils Approuvés**

Type d'Appareil

Compteurs Électrique: Énergie

Objet

La présente lettre vise à expliquer les détails des modifications apportées aux compteurs dont le type a déjà été approuvé par Mesures Canada. Ces modifications ont été évaluées par le Laboratoire des services d'approbation en conformité aux exigences nationales et doivent être considérées comme faisant partie de la portée des avis d'approbation d'origine énumérés dans le présent document et de toutes leurs révisions subséquentes.

Portée

Les modifications décrites dans la présente lettre s'appliquent aux compteurs visés par les avis d'approbation suivant:

Numéros d'approbation


AE-1631

Requérant

Itron Canada, Inc.
2624 Dunwin Dr, Unit 4
Mississauga, Ontario
Canada, L5L-3T5

Descriptions des modifications

La nouvelle base du compteur OpenWay CENTRON monophasé des forms 1S, 2S et 12S réseau a été approuvée. La nouvelle base n'a pas un bouchon utilisé pour couvrir l'ouverture du conducteur d'essai. L'ouverture va être moulée dans la prise.



Copie authentique signée par:

Isabelle Tremblay

Gestionnaire de laboratoire - Mesure de l'électricité