



Measurement Canada  
An Agency of Industry Canada

Mesures Canada  
Un organisme d'Industrie Canada

MAL No. - N° De LAM

**MAL-E115**

Date: June 20, 2006

File number: 26681-AP-AE-06-0012

## **MODIFICATION ACCEPTANCE LETTER (MAL) FOR Approved Meters and Devices**

### **Type of Device**

Electricity Meter: Energy and Demand

### **Purpose**

The purpose of this letter is to convey details of modifications to meters which have previously received approval of type recognition from An agency of Industry Canada. These modifications have been evaluated by the Approval Services Laboratory in accordance with national requirements and shall be considered to be included within the scope of the originally issued Notices of Approval specified in this document and any subsequent revisions to these Notices of Approval.

### **Scope**

The modifications described in this letter affect meters identified in the following Notices of Approval:

### **Approval Numbers**

AE-1059

### **Applicant**

General Electric Co.  
1130 Boul. Charest, ouest  
Québec, Québec  
G1N 1E2

### **Description of Modifications**

Version 4.0 is included in the list of approved firmware.

Original signed by:

Claude G. Renaud  
Technical Coordinator – Electricity Measurement



Measurement Canada  
An agency of Industry Canada

Mesures Canada  
Un organisme d'Industry Canada

MAL No. - N° De LAM

**MAL-E115**

Date: 20 juin 2006

Dossier: 26681-AP-AE-06-0012

## **LETTRE D'ACCEPTATION DE MODIFICATION (LAM)**

**pour**

**Compteurs et Appareils Approuvés**

### **Type d'Appareil**

Compteurs Électrique: Énergie et puissance

### **Objet**

La présente lettre vise à expliquer les détails des modifications apportées aux compteurs dont le type a déjà été approuvé par Mesures Canada. Ces modifications ont été évaluées par le Laboratoire des services d'approbation en conformité aux exigences nationales et doivent être considérées comme faisant partie de la portée des avis d'approbation d'origine énumérés dans le présent document et de toutes leurs révisions subséquentes.

### **Portée**

Les modifications décrites dans la présente lettre s'appliquent aux compteurs visés par les avis d'approbation suivant:

### **Numéros d'approbation**

AE-1059

### **Requérant**

General Electric Co.  
1130 Boul. Charest, ouest  
Québec, Québec  
G1N 1E2

### **Descriptions des modifications**

La version du progiciel 4.0 a été ajoutée à la liste des versions approuvées.

Copie authentique signée par :

Claude G. Renaud  
Coordonnateur technique – Mesure de l'électricité